



SECTION A-A

NOTES :

1. ANCHOR BLOCKS SHALL BE USED WHERE THE PIPE SLOPE IS STEEPER THAN 1 IN 6 AND PIPE LENGTH IS GREATER THAN 15m.
2. ANCHOR BLOCKS SHALL BE LOCATED AT NEAREST JOINT :
 - (i) APPROXIMATELY 2400mm FROM THE LOWER END THEN AT
 - (ii) 6m SPACING FOR LENGTHS 15m-30m OR
 - (iii) 10m SPACING FOR LENGTHS 30m-40m OR
 - (iv) 15m SPACING FOR GREATER THAN 40m.
3. CONCRETE STRENGTH TO BE 25MPa AT 28 DAYS

Amendments			
No.	Zone	Detail	Date

DRAWN : D. SALAZAR
 CHECKED : S. BHALLA
 APPROVED : S. PLATER
 SCALE : 1:20
 ISSUE DATE: JUNE 2004



P.O. Box 119
 1079 Pascoe Vale Road
 Broadmeadows
 Victoria 3047
 Telephone
 (03) 9205 2200
 Facsimile
 (03) 9309 0109

TYPE :

ANCHOR BLOCK
 FOR PIPES UP TO 600mm DIA.

DRAWING NO: SD284