



NOTES:

1. ALL WALLS TO BE 150mm THICK.
2. FOR PRECAST CONCRETE LINTEL DETAILS REFER TO STD. DWG. SD270
3. FOR PRECAST CONCRETE COVER DETAILS REFER TO STD. DWG. SD275
4. THE TOP OF THE PIT SHALL MATCH THE NATURE STRIP CROSSFALL
5. FLUTES TO BE PROVIDED TO PITS, WHERE KERB AND CHANNEL GRADE EXCEEDS 2%
6. PIT TO BE HAUNCHED FOR PIPE DIAMETER GREATER THAN 450mm OR DEPTH EXCEEDING 2.0m, REFER TO STD. DWG. SD245
7. PROVIDE STEP IRONS FOR PIT DEPTH EXCEEDING 1.0m, REFER TO STD. DWG. SD280.
8. CONCRETE STRENGTH 25Mpa AT 28 DAYS
9. EXPANSION JOINTS TO BE INSTALLED EITHER SIDE OF PIT WITH 3 No. 450mm LONG R16 BARS GREASED OR SLEEVED ONE END.

RESTRICTED USE ONLY.
GENERALLY ONLY USED FOR
RECONSTRUCTION WORKS.
ONLY TO BE USED IN SPECIAL CASES.

			DRAWN :	S. GUCH
	Initials	Date	CHECKED :	R. DEVAPURA
NOTE No.9 ADDED	R.C.	JAN 05	APPROVED :	S. PLATER
			SCALE :	
			ISSUE DATE:	JUNE 2004



P0 Box 119
1079 Pascoe Vale Road
Broadmeadows
Victoria 3047

Telephone
03) 9205 2200

Focsimile
03) 9309 0109

SIDE ENTRY PIT
SEMI MOUNTABLE KERB & CHANNEL

DRAWING NO: SD205