

2. GRATE TO BE HOT DIPPED GALVANIZED STEEL OR CAST IRON.

3. STEP IRONS TO BE PROVIDED IN PITS OVER 1m DEEP. REFER TO STD. DWG. SD280.

4. THE TOP OF THE PIT SHALL MATCH THE NATURE STRIP CROSSFALL.

5. CONCRETE TO BE 25MPa AT 28 DAYS.

6. PIT TO BE HAUNCHED FOR PIPE DIAMETERS GREATER THAN 450mm OR DEEPER THAN 2.0m REFER TO STD. DWG. SD245.

7. IN RESERVES WHERE AN APRON IS REQUIRED AND OPEN EARTH CHANNELS PROVIDE A 150 THICK X 450mm WIDE CONCRETE APRON WITH 150 MAXIMUM DROP TO TOP OF GRATE.

Amendments				DRAWN :	D. SALAZAR
No.	Detail	Initials	Date		5 55 45 54 54
Α				CHECKED :	R. DEVAPURA
				APPROVED :	S. PLATER
		-		SCALE :	N.T.S.
				ISSUE DATE:	JUNE 2004



PO Box 119 1079 Pascoe Vale Road Broadmeadows Victoria 3047

SECTION

Telephone 03) 9205 2200

Facsimile 03) 9309 0109 TYPE :

A-A

GRATED PIT IN RESERVES, CHANNELS AND PAVED AREAS

DRAWING NO:

SD225